



Fire Life Safety Bulletin

FLSB #2020-03

MISSING STANDPIPE CONNECTIONS

August 18, 2020

MISSING STANDPIPE SWIVELS AND CAPS

WMATA's Office of Emergency Management has been notified of several missing standpipe swivels and caps throughout the system. In particular, the downtown area of Washington, DC.

Departments are encouraged to check their respective areas- not just Metro stations, but all buildings requiring standpipe or sprinkler connections as this has been found to not be solely limited to WMATA property. Metro Transit Police has launched an investigation into the matter.

If any caps or connections are found to be missing or damaged on WMATA property contact any OEM member listed below so repairs can be made as soon as possible.



For additional information, contact one of the Office of Emergency Management Fire/Life Safety Officers:

John Keller	(202) 689-5047	jkeller@wmata.com
Walt Lanier	(202) 841-4705	wlanier@wmata.com
Steve Fennell	(202) 897-9684	sfennell@wmata.com
Robert Joy	(202) 329-7654	rjoy@wmata.com
Nathan Kempfer	(202) 313+8385	jnkempfer@wmata.com